

2.15

PART NUMBERS

11960-X06 11960-X12 11960-X18 11961-X06 11961-X12 11961-X18 11962-X06 11962-X12 11962-X18

11963-X06 11963-X12 11963-X18 11964-X06 11964-X12 11964-X18 11965-X06 11965-X12 11965-X18

SHEET 1

COMPONENTS


Item	Quantity	Component Description	
Α	4	Wall Attachment Brackets (Legs)	
В	2	Cross Members	
С	2	Mounting Channels	
D	4	Corner Assembly Brackets	
Е	16	1/4" - 20 x 5/8 Hex Bolts	
F	16	1/4" - 20 Hex Nuts	
G	8	1/4" x 2" Hex Lag Screws (not shown)	
Н	50 pack	#12 - 24 Mounting Screws (not shown)	
	oo paak	" 12 2 : Modificing Colonic (not show	

Note: Wall-mount rack must be secured using all possible hex lag screws (G) provided to 3/4" plywood back-board secured to wall framing to assure load bearing capability. Lag screws are intended for mounting to wooden surface; for masonry surface, the installer must provide appropriate hardware.



INSTALLATION INSTRUCTIONS **FIXED WALL-MOUNT EQUIPMENT RACK**

THIS DRAWING CONTAINS INFORMATION PROPRIETARY TO CHATSWORTH PRODUCTS, INC. ANY REPRODUCTION DISCLOSURE OR USE OF THIS DRAWING IS EXPRESSLY FORBIDDEN EXCEPT AS AGREED TO IN WRITING BY CHATSWORTH PRODUCTS, INC



PART NUMBERS

 11790-X12
 11790-X18
 11790-X25
 11793-X12
 11793-X18
 11793-X25


 11791-X12
 11791-X18
 11791-X25
 11794-X12
 11794-X18
 11794-X25

 11807-X12
 11807-X18
 11808-X12
 11808-X18
 11808-X25

 11792-X12
 11795-X18
 11795-X18
 11795-X25

INSTRUCTIONS

- Step 1 Loosen hex bolt on pre-installed corner ramp (D) and wall attachment cross-member (B).
- **Step 2** Slide legs (A) into position with slots fitting under previously loosened bolts.
- Step 3 Tighten all bolts and install remaining hex bolts and hex nuts through remaining alignment holes with a 7/16" socket wrench.
- **Step 4** Use a level to assure wall rack is level while securing to wall.
- **Step 5** Align lower pivot pins of mounting frame (C) into lower corner ramps. Retract upper pivot pins and secure in upper corner ramps.



COMPONENTS			
Item	Quantity	Component Description	
Α	2	Wall Attachment Brackets (Legs)	
В	2	Wall Attachment Cross-Members	
С	1	Mounting Frame	
D	4	Corner Assembly Ramps (pre-installed in cross-members)	
Е	16	1/4" - 20 x 5/8 Hex Bolts	
F	16	1/4" - 20 Hex Nuts	
G	8	1/4" x 2" Hex Lag Screws (not shown)	
Н	50 pack	#12 - 24 Mounting Screws	

Note: Wall-mount rack must be secured using all possible hex lag screws (G) provided to 3/4" plywood back-board secured to wall framing to assure load bearing capability. Lag screws are intended for mounting to wooden surface; for masonry surface, the installer must provide appropriate hardware.



SHEET 2

INSTALLATION INSTRUCTIONS STANDARD SWING GATE WALL RACK

THIS DRAWING CONTAINS INFORMATION PROPRIETARY TO CHATSWORTH PRODUCTS, INC. ANY REPRODUCTION DISCLOSURE OR USE OF THIS DRAWING IS EXPRESSLY FORBIDDEN EXCEPT AS AGREED TO IN WRITING BY CHATSWORTH PRODUCTS, INC.

